



# ALS Group USA, Corp.

3337 Michelson Drive, Suite CN750, Irvine, CA 92612

## Certified Product Listing

**For:**

Drinking Water System Components - Health Effects

**Company:**

SealBoss Corporation  
1669 E Wilshire Avenue  
Santa Ana, CA 92705, United States

**Plant Location:**

Santa Fe Springs, CA, United States

**Standards:**

NSF/ANSI/CAN 61 - 2020

**Certificate:**

Issued Date: 12/07/2021

**Material/Product:**

SealBoss 1570LV WaterStopFoam

**Contact Temperature:**

23 ± 2°C

**Models:**

SealBoss 1570LV WaterStopFoam

The crack filler should not exceed more than 5% coverage of the total surface area.



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.

ALS Group's Product Certification Listing directory contains the most current certified product(s) and supersedes all printed copies of the listings.



# ALS Group USA, Corp.

3337 Michelson Drive, Suite CN750, Irvine, CA 92612

## Material Characteristics:

Minimum tank size (gallons): 1000

Maximum tank surface area/volume ratio (sq in/L): 5.7

Is additional coating required (e.g. top coat, primer, intermediate coat)? (Y/N): Refer to manufacturer instructions for details

Final cure time: 24 hours @ ambient temperature

Mix ratio: 10:1:1

Is this paint/coating system intended to be applied to a pipe? (Y/N): No

Additional comments:

The crack filler should not exceed more than 5% coverage of the total surface area.



Product certified to NSF/ANSI/CAN 372 conforms to the requirements for "Lead Free" plumbing products as defined by California, Vermont, Maryland and Louisiana state laws and by section 1417 of the US SDWA.

ALS Group's Product Certification Listing directory contains the most current certified product(s) and supersedes all printed copies of the listings.

Page 2/2